

Via D. Alighieri 33 29010 Villanova sull'Arda (PC) - Italy Tel. 0039.0523.837899 Fax 0039.0523.837381

UNI EN ISO 9001-2015 Certified

Data Sheet









K-FLEX 2000 H.F CONTROL

Description: Halogen Free multi-conductors connecting and control cable with colour code cores Design: Construction: Flexible bare copper conductors according to CEI 20-29 Class 5 and DIN-VDE 0295 K5 Halogen free insulation compound type TI6 according to HD 21.14 S1 annex A Colour coded as per VDE 0293 and HD 308 Halogen free jacket compound type TM7 according to HD 21.14 S1 annex B Manufacturing's Test and Control according to our certificated ISO 9001-2015 CSQ-IMQ (EQ-NET) Controls: Quality System procedure. Labor tests reports are stored in our internal Q.C. laboratory archive together with the production reports Norms: Flame-retardant according to IEC 60332-1-2 (flame spread on a single cable) No flame-propagation according to IEC 60332-3-24 respectively IEC 60332-3-25 (Flame spread on vertical cable or wire bundle) Halogen-free according to IEC 60754-1 (amount of halogen acid gas) Corrosiveness of combustion gases according to IEC 60754-2 (degree of acidity) Low smoke density according to IEC 61034 The cable is conform to Low Voltage Directive (LVD) 2014/35/EU CE Technical dates: Nominal voltage: 300/500V 3000V Spark Test voltage: Working temperature: Occasional flexing: -15°C to +70°C Fixed installation: -40°C to +70°C Minimum bending radius Occasional flexing: 15 x outer Ø Fixed installation: $4 \times \text{outer } \emptyset$ Environmentally friendly, halogen-free Power Connecting and Control Cable especially for Use: electrical equipment and installations in industrial environments, dry or damp interiors. Suitable for fixed installation under medium mechanical load conditions as well as for flexing application at free, non-continuously recurring movement without tensile load or compulsory quidance. Outdoor use with UV-protection only, considering the temperature range. Particularly suitable where human and animal life as well as valuable property are exposed to high risk of fire hazards.