

Via D. Alighieri 33 29010 Villanova sull'Arda (PC) - Italy Tel. 0039.0523.837899 Fax 0039.0523.837381



UNI EN ISO 9001-2015 Certified Company









K-FLEX 2200 H.F. H05Z1Z1-F CPR Cca

Description: Harmonized Halogen Free multi-conductors connecting and control cable with colour code cores 300/500 V. Design: Flexible bare copper conductors according to CEI 20-29 Class 5 and DIN-VDE 0295 K5 Construction: Halogen free insulation compound type TI6 according to HD 21.14 S1 annex A Coloured coded cores according to HD 308 Halogen free jacket compound type TM7 according to HD 21.14 S1 annex B Test and Control according to our certificated ISO 9001-2015 CSQ-IMQ (EQ-NET) Manufacturing's Quality System procedure. Controls: Labor tests reports are stored in our internal Q.C. laboratory archive together with the production reports Norms: Flame-retardant according to IEC 60332-1-2 (flame spread on a single cable) No flame-propagation according to IEC 60332-3-24 respectively IEC 60332-3-25 (Flame spread on vertical cable or wire bundle) Halogen-free according to IEC 60754-1 (amount of halogen acid gas) Corrosiveness of combustion gases according to IEC 60754-2 (degree of acidity) Low smoke density according to IEC 61034 According to HD 21.14 51 CPR classification: Cca, s1, d1, a1 (It satisfies the non-flame propagation test, with the requirement of non-fire propagation and with emitted heat limits for this class) The cable is conforming to Low Voltage Directive (LVD) 2014/35/EU CE Nominal voltage: 300/500V Technical dates: Spark Test voltage: 3000 V Working temperature: Occasional flexing: -15°C to +70°C Fixed installation: -40°C to +70°C Minimum bending radius Occasional flexing: 15 x outer Ø Fixed installation: $4 \times \text{outer } \emptyset$ K-FLEX 2200 H.F. H05Z1Z1-F cables are used in applications as extension and connecting Use: cables for electrical devices, appliances and machinery, where plugs must be permanently connected to the corresponding cable. Particularly suitable where human and animal life as well as valuable property are exposed to high risk of fire hazards.